ANALYTICAL REPORT

Montana Environmental Laboratory LLC
1170 N. Meridian Rd., P.O. Box 8900, Kalispell, MT 59904-1900
Phone: 406-755-2131 Fax: 406-257-5359

RECEIVED
JUL 2 2 2008
COM ED DIV.

Yaak Rod & Gun Club
22266 Yaak River Rd
Troy, MT 59935

PWS ID:
Project:

Client Sample ID: Rod & Gun Club
Matrix: DRINKING WATER **Collected:** 06/17/2008 9:30

Lab ID: 0805149-01
Received: 06/19/2008 9:00

Analyses	Result	Units	MDL	MCL	Method	Prepared	Analyzed	Analyst
Antimony	ND	mg/L	0.003	0.006	E200.8		06/28/2008 13:49	EL
Arsenic	ND	mg/L	0.001	0.010	E200.9		06/25/2008 8:08	LKN
Barium	ND	mg/L	0.1	2	E200.8		06/28/2008 13:49	EL
Beryllium	ND	mg/L	0.001	0.004	E200.8		07/01/2008 13:49	EL
Cadmium	ND	mg/L	0.001	0.005	E200.8		06/28/2008 13:49	EL
Chemical Oxygen Demand (COD)	ND	mg/L	1		E410.1		06/19/2008 14:12	MKC
Chloride	0.8	mg/L	0.1	250	E300		06/24/2008 12:39	LKN
Chromium	ND	mg/L	0.01	0.1	E200.8		06/28/2008 13:49	EL
Cobalt	ND	mg/L	0.01	0.1	E200.8		06/28/2008 13:49	EL
Conductivity	412	umhos/cm	0.1		SM2510B		06/19/2008 15:03	MKC
Copper	ND	mg/L	0.01	1.3	SM3111B		06/30/2008 16:57	JC
Cyanide, Total, Automated	ND	mg/L	0.005	0.2	Kelada mod		06/24/2008 13:49	EL
Iron	2.00	mg/L	0.03	0.3	200.7		06/30/2008 16:36	JC
Lead	0.002	mg/L	0.001	0.015	E200.9		07/01/2008 8:11	JC
Mercury	ND	mg/L	0.0002	0.002	E245.1		06/30/2008 13:49	EL
Nickel	ND	mg/L	0.01	1	E200.8		06/28/2008 13:49	EL
Nitrate + Nitrite, Total	0.06	mg/L	0.01	10	353.2		06/24/2008 12:39	LKN
pH	7.76	pH	0.1		150.1		06/19/2008 14:02	MKC
Selenium	ND	mg/L	0.005	0.05	E200.8		06/28/2008 13:49	EL
Silver	ND	mg/L	0.005	0.1	E200.8		07/01/2008 13:49	EL
Sulfate	2.5	mg/L	0.1	500	E300.0		06/24/2008 12:39	LKN
Thallium	ND	mg/L	0.001	0.002	E200.8		06/28/2008 13:49	EL
Vanadium	ND	mg/L	0.1	NR	E200.8		06/28/2008 13:49	EL
Zinc	0.03	mg/L	0.01	5	E200.8		06/28/2008 13:49	EL

MCL = Maximum Contaminant Limit
RL = Reporting Limit
ND = Not Detected
NR = Not Regulated

MEL REVIEW: JMC

ANALYTICAL REPORT

Montana Environmental Laboratory LLC
1170 N. Meridian Rd., P.O. Box 8900, Kalispell, MT 59904-1900
Phone: 406-755-2131 Fax: 406-257-5359

Volatile Organic Compounds - Long List

Yaak Rod & Gun Club
22266 Yaak River Rd
Troy, MT 59935

PWS ID:
Project:

Client Sample ID: Rod & Gun Club

Lab ID: 0805149-01

Date Received	Date Collected	Date Prepared	Date Analyzed	Matrix	Sample Amount	Dilution Factor	Units	Method	Analyst
6/19/2008 9:00	6/17/2008 9:30		6/25/2008 13:45	DRINKING WATER	1	1	µg/L	SW8260B	EL

Parameter	Result	RL	Parameter	Result	RL
Acetone	ND	20	Dichlorodifluoromethane	ND	1.0
Acrylonitrile	ND	20	1,1-Dichloroethene	ND	1.0
Allyl chloride	ND	20	1,2-Dibromoethane (EDB)	ND	1.0
Benzene	ND	1.0	1,1-Dichloroethane	ND	1.0
Bromobenzene	ND	1.0	cis-1,2-Dichloroethene	ND	1.0
Bromochloromethane	ND	1.0	trans-1,2-Dichloroethene	ND	1.0
Bromodichloromethane	ND	1.0	1,2-Dichloropropane	ND	1.0
Bromoform	ND	1.0	1,1-Dichloropropanone	ND	1.0
Bromomethane	ND	1.0	1,3-Dichloropropane	ND	1.0
n-Butylbenzene	ND	1.0	2,2-Dichloropropane	ND	1.0
sec-Butylbenzene	ND	1.0	1,1-Dichloropropene	ND	1.0
tert-Butylbenzene	ND	1.0	cis-1,3-Dichloropropene	ND	1.0
Carbon disulfide	ND	1.0	trans-1,3-Dichloropropene	ND	1.0
Carbon tetrachloride	ND	1.0	Diethyl ether	ND	1.0
Chloroacetonitrile	ND	1.0	Ethylmethacrylate	ND	1.0
Chlorobenzene	ND	1.0	Ethylbenzene	ND	1.0
1-Chlorobutane	ND	1.0	Hexachlorobutadiene	ND	1.0
Chlorodibromomethane	ND	1.0	Hexachloroethane	ND	1.0
Chloroethane	ND	1.0	2-Hexanone	ND	20
Chloroform	ND	1.0	Iodomethane	ND	1.0
Chloromethane	ND	1.0	Isopropylbenzene	ND	1.0
2-Chlorotoluene	ND	1.0	p-Isopropyltoluene	ND	1.0
4-Chlorotoluene	ND	1.0	Methyl acrylate	ND	1.0
1,2-Dibromo-3-chloropropane	ND	1.0	Methylacrylonitrile	ND	1.0
Dibromomethane	ND	1.0	Methyl ethyl ketone	ND	20
1,2-Dichloroethane	ND	1.0	Methyl isobutyl ketone	ND	20
1,2-Dichlorobenzene	ND	1.0	Methyl methacrylate	ND	1.0
1,3-Dichlorobenzene	ND	1.0	Methyl tert-butyl ether	ND	1.0
1,4-Dichlorobenzene	ND	1.0	Methylene chloride	ND	1.0
trans-1,4-Dichloro-2-butene	ND	1.0	Naphthalene	ND	1.0

MCL = Maximum Contaminant Limit **ND = Not Detected**
RL = Reporting Limit **NR = Not Regulated**

MEL REVIEW: JRL

ANALYTICAL REPORT

Montana Environmental Laboratory LLC
1170 N. Meridian Rd., P.O. Box 8900, Kalispell, MT 59904-1900
Phone: 406-755-2131 Fax: 406-257-5359

Volatile Organic Compounds - Long List

Yaak Rod & Gun Club
22266 Yaak River Rd
Troy, MT 59935

PWS ID:
Project:

Client Sample ID: Rod & Gun Club — Lab ID: 0805149-01

Date Received	Date Collected	Date Prepared	Date Analyzed	Matrix	Sample Amount	Dilution Factor	Units	Method	Analyst
6/19/2008 9:00	6/17/2008 9:30		6/25/2008 13:45	DRINKING WATER	1	1	µg/L	SW8260B	EL

Parameter	Result	RL	Parameter	Result	RL
Nitrobenzene	ND	1.0			
2-Nitropropane	ND	1.0			
Pentachloroethane	ND	1.0			
Propionnitrile	ND	1.0			
n-Propylbenzene	ND	1.0			
Styrene	ND	1.0			
1,1,1,2-Tetrachloroethane	ND	1.0			
1,1,2,2-Tetrachloroethane	ND	1.0			
Tetrachloroethene	ND	1.0			
Tetrahydrofuran	ND	1.0			
Toluene	ND	1.0			
1,2,3-Trichlorobenzene	ND	1.0			
1,2,4-Trichlorobenzene	ND	1.0			
1,1,1-Trichloroethane	ND	1.0			
1,1,2-Trichloroethane	ND	1.0			
Trichloroethene	ND	1.0			
Trichlorofluoromethane	ND	1.0			
1,2,3-Trichloropropane	ND	1.0			
Total Trihalomethanes	ND	1.0			
1,2,4-Trimethylbenzene	ND	1.0			
1,3,5-Trimethylbenzene	ND	1.0			
Vinyl chloride	ND	1.0			
m & p Xylene	ND	1.0			
o-Xylene	ND	1.0			
Total Xylenes	ND	1.0			

MCL = Maximum Contaminant Limit **ND = Not Detected**
RL = Reporting Limit **NR = Not Regulated**

MEL REVIEW: JMC