



Montana Fish, Wildlife & Parks

ADDENDUM NO. 1

TO: ALL BIDDERS OF RECORD

PROJECT: Hell Creek State Park Infrastructure Upgrades

FWP PROJECT #: 7116507

DATE: **March 29, 2018**

FROM: Darcy Yakoweshen, Montana FWP Project Manager

Acknowledge receipt of this addendum by inserting its number and date in the Proposal Form and on the Bid Envelope. Failure to do so may subject bidder to disqualification.

This Addendum forms a part of the Contract Documents. Clarification and/or modifications area as follows:

1. **Modification:** The public bid opening date for this project has been moved from April 10, 2018 to April 18, 2018. Bids will be accepted until 3:00 p.m. on April 18, 2018.
2. **Section 00910 – Special Provisions:** Strike the reference to “Article 3.01 of the Instructions to Bidders” in SP-02 and replace with “Article 8.4 of the Instructions to Bidders”.
3. **Section 00910 – Special Provisions:** Delete SP-17 and replace with the following.

SP-17 CONSTRUCTION SEQUENCING

The project has two contract periods.

1. Procuring of equipment and materials to be used for site construction; and
2. On-site construction of the Work.

The Notice to Proceed will be issued at the Contractor’s request any time after the Contract is fully executed. The procurement of equipment and materials period shall begin upon the Notice to Proceed being issued. The on-site construction period may not begin until **August 15, 2018 at the earliest** and the final start date must be

coordinated with and approved by the Owner prior to any construction activities taking place.

All existing water, sewer, and fish cleaning station operation shall remain operable for the public until October 1, 2018, and no work will be allowed near the fish cleaning station prior to this date. After October 1, 2018, the Contractor shall make connections, test, and demonstrate the operation of new systems. Once the new system is approved for Substantial Completion, the Contractor shall winterize the new tank and pumping system, the fish cleaning station, the lift station, and any other new component susceptible to damage from freezing.

4. **Detail 1, Sheet 15 of the Drawings:** Add the following note to Detail 1 on Sheet 15.

Provide an E-One Extreme Series WH-482-92 pump station designed to pump up to 3,500 gallons of wastewater per day at a design point of 11.3 gpm at 85 feet TDH or an approved equivalent.

5. **Sheet 19 of the Drawings:** The dose tank needs to have a 3,000 gallon capacity as indicated in the Bid Proposal and Section 01275 – Measurement and Payment. Update the titles of Details 1 and 2 on Sheet 19 accordingly.

END OF ADDENDUM NO. 1