

ADDENDUM #2

**Libby Area Office
Storage Building
FWP #7179101**


Near Libby, Montana

April 12, 2018

Bidders for the above listed project are hereby notified that the following changes have been made to the bid documents:

1. Modify **TECHNICAL SPECIFICATION – SECTION 08 3613 SECTIONAL DOORS, 2.02.B** *as follows*

Replace all references to 20 gage, 0.0359 inch minimum thickness with 0.015 inch minimum thickness.



Jeffrey L. Larson, P.E.

PLEASE ACKNOWLEDGE RECEIPT OF THIS ADDENDUM ON THE DESIGNATED PLACE IN THE BID FORM AND ON THE FACE OF THE ENVELOPE.