

**ADDENDUM NO. 1**  
**TIBER RESERVOIR MARINA WATERCRAFT INSPECTION STATION**  
**FWP PROJECT # 7193603**  
**ADDENDUM DATE: JUNE 26, 2019**  
**BID TIME & DATE: 3:00 P.M.; JULY 2, 2019**

**NOTICE TO ALL BIDDERS**

The Contract Documents, Plans and Specifications are hereby modified as follows, and in submitting their bid, each bidder shall acknowledge receipt of all addenda which will become part of the Contract Documents.

**RESPONSES TO QUESTIONS**

Note: Q = Question and R = Response

1. **Q:** Can water from Tiber Reservoir be utilized by the Contractor for construction water (compaction and dust control)?  
**R:** Yes. The Contractor will need to coordinate the location for filling of water trucks from Tiber Reservoir with the Bureau of Reclamation (BOR) staff. Possible filling locations include along Lake Elwell Road where it crosses over to the "island" west of the project site or the Tiber Reservoir Marina southeast of the site. Contact information for the BOR will be provided to the Contractor.
  
2. **Q:** Will PVC conduit be required for all electrical conductor runs to the RV pedestals?  
**R:** Yes, the intent is for all "URD" conductor to be installed in PVC conduit to all of the new RV electrical pedestals. Direct burial of the conductor will not be allowed.
  
3. **Q:** Is the project site located within designated sage grouse habitat?  
**R:** No, it has been confirmed that the site is not located within a Montana Sage Grouse Habitat Conservation Program designated area.

**ACKNOWLEDGEMENT OF ADDENDUM NO. ONE (1)**

The bidder shall acknowledge receipt of Addendum No. One (1) on the Bid Form and Envelope.

Issued By:

  
\_\_\_\_\_

**END OF ADDENDUM NO. 1**