



MONTANA FISH, WILDLIFE & PARKS

ADDENDUM NO. 2

TO: ALL BIDDERS OF RECORD

PROJECT: Freezout Lake WMA Water Control Structures

FWP PROJECT #: 7215405

DATE: July 1, 2026

FROM: Kevin Harrington, Project Manager

Acknowledge receipt of this addendum by inserting its number and date in the Proposal Form and on the Bid Envelope. Failure to do so may subject bidder to disqualification.

This Addendum forms a part of the Contract Documents. Bidders for the above listed project are hereby notified that the following changes have been made to the bid documents:

CLARIFICATION:

ITEM #4 INSTALLATION NEW HEADWALL W/ STOPLOGS

- As noted in section 24 of the special provisions un “measure and pay” the rebar is incidental to the cost of Item #4.
- #6 Rebar shall be installed within the footing on 12”centers and throughout the headwall. Rebar hooks from head wall also installed on 12” centers.

END OF ADDENDUM NO. 2